

TRIMO D.O.O.

PRIJATELJEVA CESTA 12
8210 TREBNJE | SLOVENIA
T: +386 (0)7 34 60 200
F: +386 (0)7 34 60 127
TRIMO@TRIMO-GROUP.COM
WWW.TRIMO-GROUP.COM

Date: 04.12.2024

Subject: VOCs statement: Comparison with limit value of BREEAM International

To whom it may concern:

We hereby declare that Trimo d.o.o. has performed analysis and measurements of emissions of volatile organic compounds (VOC) for the products **Qbiss One and Trimoterm**. All tests have been carried out in an accredited test laboratory according to EN 16516 and ISO 16000-6. The testing methods are accredited in accordance with EN ISO/IEC 17035.

Trimo declares that all measurements and compounds content for **Qbiss One and Trimoterm** products with typical internal steel sheet have been found to be below the minimum levels required for building materials for indoor use, according to basic level for BREEAM International New Construction v2.0 (2016).

Parameter	Value after 28 days
Formaldehyde	$\leq 0,06 \text{ mg/m}^3$
TVOC (EN 16516)	$\leq 0,3 \text{ mg/m}^3$
TSVOC	$\leq 0,1 \text{ mg/m}^3$
Total carcinogens	$\leq 0,001 \text{ mg/m}^3$

Should you require any further clarifications or information do not hesitate to contact us.

Robert Ajdič
Head of Quality department

TRIMO
TRIMO D.O.O.
PRIJATELJEVA CESTA 12
8210 TREBNJE

2